

R-1C COMPLAINT FORM

PLANT PROTECTION DEPARTMENT
GENERAL COMPLAINT REPORT

PSW-88-2

Officer's Name: (Last, First, Init.) Martin, William G. Shield 5 Date/Time of Incident 1-12-88 8:50pm Location of Incident Hazardous Waste Bldg.
Type of Complaint (Check One) Accident ☐ Alarm ☐ Facility ☒ General ☐ Security ☐
Parking ☐ Medical ☐ Other (specify) ☐

Complainant: (Last, First, Init.) Clock or SS# Dept. or Company Shift Telephone/Ext.
Non-Employee's Address Street City State Zip Code

Description: (Who, What, When, Where, Why, How)
While performing Detex clock round writer discovered a frozen water line had
ruptured inside the Hazardous Waste Building. About 3 inches of water covered
the entire floor.

Action Taken:
Maintenance Foreman, George Montowski and Supervisor Warren were notified.
They turned off the water supply. There was no visable damage.

Robert Francis was notified at his home regarding the above. He gave George
Montowski an okay to pump out the water.

Copies to:
I.S.I.D.
H.A.S.E.
File:
Personnel:
Medical:
Operation:
Plant Eng.:

Officer's Signature: William G. Martin Date: 1-13-88
William G. Martin

Approval By: Vern Warren Date: 1-13-88
Vernon Warren, Supervisor
IFC Plant Protection

cc: D. Arner
R. Francis
V. Petraglia
D. Villella